JUPITER PRIME

Consulting • Training • Advisory

جوبيتر برايم للاستشارات والتدريب

COURSE BROCHURE

Fire Water Hydraulic Calculation Using PIPENET Training Course

23 – 27 November 2026
Rome

Fire Water Hydraulic Calculation Using PIPENET Training Course

Ref: 585_21591 **Date:** 23 – 27 November 2026 **Location:** Rome **Fees:** 7200 GBP

Fire Water Hydraulic Calculation Using PIPENET Training Course is a 1-week training course for process safety engineers, fire protection design leads, piping stress specialists, and loss prevention consultants, and each participant prepares a Fire Protection Hydraulic Network Analysis Dossier. Complex petrochemical plants and offshore platforms demand rigorous verification that emergency water supplies achieve design densities under concurrent disaster scenarios. Jupiter Prime Training delivers this Fire Water Hydraulic Calculation Using PIPENET course to build operational certainty across high-hazard industrial assets.

Why Fire Water Hydraulic Calculation Using PIPENET Matters Now

Energy transition initiatives, facility expansions, and intensifying chemical processing risks challenge the delivery capacity of ageing underground fire mains and high-hazard fixed deluge systems. Inadequate hydraulic design risks localized flow starvation, component rupture during transient surges, and regulatory non-compliance during major hazard safety reviews. Modern industrial safety requires multi-scenario modelling that balances hydraulic demand with available supply while controlling line velocities and pipe pressure drops. Grounded in National Fire Protection Association codes including NFPA 15 for water spray fixed systems, NFPA 20 for stationary fire pumps, and NFPA 24 for dedicated service mains, structured network simulation reconciles steady-state sizing with transient surge mitigation across complex chemical and energy assets.

Who Gains Most from Fire Water Hydraulic Calculation Using PIPENET

- Fire protection design engineers responsible for sizing ring mains, deluge valves, foam-water skids, and discharge nozzles across process units
- Process safety leads evaluating worst-case contingency water demands, fireproofing credit assumptions, and simultaneous envelope cooling requirements
- Piping system hydraulic specialists tasked with specifying pump heads, pipe diameters, control valve characteristics, and surge mitigation measures
- Asset integrity coordinators verifying physical fire water ring performance, corrosion allowances, and valve throttling configurations across aged pipework

A multidisciplinary engineering cohort comprising process safety engineers, piping leads, and fire protection specialists gains most, as shared participation aligns hazard envelope definitions with network sizing calculations and hydraulic margin verification.

Fire Water Hydraulic Calculation Using PIPENET Capabilities

Participants gain rigorous hydraulic calculation competencies, applying specialised software algorithms to model, balance, and verify emergency water systems across onshore refineries and offshore oil installations.

- Assess fire water system demand profiles against hazard footprints — plant boundary protection and process equipment exposure
- Model loop networks and tree topologies using Hazen-Williams and Darcy-Weisbach formulations — pressure distribution and pipe friction loss verification
- Size fixed spray nozzles and deluge rings to deliver required application densities — compliance with prescriptive safety design rules
- Evaluate fire pump operating curves against concurrent disaster scenarios — pump head margin and hydraulic capacity adequacy
- Simulate hydraulic pressure transients and water hammer occurrences during valve closures — mechanical pipework stress and surge alleviation
- Specify line sizing, throttling orifices, and pressure-reducing valves across uneven elevations — balanced hydraulic supply across remote extremities

Key Fire Water Hydraulic Calculation Using PIPENET Terms

- Hazen-Williams Equation — An empirical hydraulic formulation calculating water head loss through pressure pipes based on diameter, flow, and internal roughness coefficients.
- Deluge System — A fixed fire suppression arrangement with open discharge nozzles fed by piping interconnected to a central fast-acting automatic valve.
- Design Area Density — The specified discharge rate of fire water per unit of protected surface area, expressed in litres per minute per square metre.
- Water Hammer — A violent hydraulic pressure surge generated when moving liquid within a closed piping circuit is abruptly forced to stop or redirect.
- Cavitation Margin — The differential between net positive suction head available and required, preventing vapour pocket formation within fire pump impellers.
- Hydraulic Balancing — Sizing pipes and introducing calibrated orifice plates to achieve uniform pressure and discharge density across all concurrent operating zones.

Fire Water Hydraulic Calculation Using PIPENET Day by Day

Day 1: Design Standards, Hazard Identification, and Demand Calculations

- NFPA 15 and NFPA 24 Frameworks — Establishing Prescriptive Flow Rates and Network Design Criteria
- Process Unit Fire Hazard Analysis — Defining Concurrent Risk Scenarios and Demand Zones
- Hydraulic Friction Loss Equations — Selecting Between Darcy-Weisbach and Hazen-Williams Formulations
- Source Water Sizing Methodology — Verifying Primary Reservoirs and Suction Tank Storage Volumes
- System Configuration Typologies — Comparing Looped Ring Mains with Branched Distribution Networks

Day 2: Hydraulic Network Modelling and Loop Balancing

- PIPENET Graphical Interface Navigation — Constructing Schematic Topology and Setting Physical Pipe Properties
- Component Elevation and Equivalent Lengths — Factoring Fittings, Strainers, and Isolation Valve Resistances
- Underground Ring Main Flow Analysis — Resolving Looped Circuit Balances and Pressure Gradients
- C-Factor Degradation Assumptions — Accounting for Long-Term Internal Corrosion and Biofouling Friction
- Hydraulic Breakpoint Identification — Locating Low-Pressure Zones Across Distant Ring Main Sectors

Day 3: Deluge, Sprinkler, and Fixed Spray System Sizing

- NFPA 13 Spray Nozzle Distribution — Matching Discharge Coefficients with Hazard Exposure Geometries
- Vessel Cooling Ring Network Layout — Modelling Curved Manifolds and Concentric Piping Topologies
- Nozzle K-Factor Selection — Optimising Discharge Density Across Unequal Process Deck Elevations
- Hydraulic Throttling Devices — Placing Orifice Plates to Prevent Flow Robbing in Localised Loops
- Foam-Water Deluge Integration — Calculating Viscous Additive Friction Losses in Proportioning Systems

Day 4: Fire Pump Station Integration and Supply Curve Matching

- NFPA 20 Centrifugal Pump Specifications — Plotting Head-Capacity Curves and Runout Limits
- Suction Line Hydraulics Assessment — Confirming Net Positive Suction Head Margins Under Minimum Levels
- Pressure Control Valve Integration — Managing Excess Delivery Pressures Across Static Standby Conditions
- Jockey Pump Sizing Protocols — Maintaining Stable Line Pressures Against Normal Gasket Leakage
- Multiple Pump Parallel Operation — Evaluating System Discharge Curves Under Single-Pump Failure Scenarios

Day 5: Hydraulic Surge, Dynamic Transients, and Calculation Dossier Finalisation

- Valve Stroke Closure Dynamics — Calculating Rapid Valve Shutoff Pressure Spikes in Ring Mains
- Surge Vessel and Alleviation Sizing — Protecting Structural Anchors from Dynamic Hydraulic Shock Loads
- Scenario Sensitivity Verification — Testing Network Redundancy Under Single-Point Isolation Conditions
- Offshore Platform and High-Rise Manifolds — Balancing Multi-Tier Deluge Systems Across Extreme Vertical Elevations
- Calculation Package Assembly — Finalising the Fire Protection Hydraulic Network Analysis Dossier

Applying Fire Water Hydraulic Calculation Using PIPENET After the Course

- Audit existing process plant fire water ring mains against updated contingency demands, identifying throttled legs and velocity excursions using hydraulic simulation software.
- Rebalance fixed deluge cooling rings on high-pressure storage vessels by recalculating orifice plate diameters and nozzle discharge coefficients to eliminate low-pressure starvation.

Fire Water Hydraulic Calculation Using PIPENET Questions FAQ

What is fire water hydraulic calculation using PIPENET and why does it matter now?

It is the numerical simulation of emergency water flow, pressure drop, and transient surges across fire protection piping networks. It matters now because industrial facilities face expanding process hazards and ageing distribution systems that require verifiable proof of adequate discharge density during concurrent fire scenarios.

Which roles gain most from fire water hydraulic calculation using PIPENET?

Process safety leads, fire systems engineers, loss prevention specialists, and mechanical piping designers gain most. The methodology equips professionals responsible for verifying that emergency pumping systems, ring distribution loops, and deluge discharge manifolds satisfy mandatory safety standards under peak demand conditions.

How does this course differ from general fluid mechanics or steady-state piping design courses?

General fluid mechanics focuses on broad thermodynamic and steady conveyance principles across general industrial pipelines. This course concentrates explicitly on emergency fire safety requirements, NFPA compliance codes, fire pump operating boundaries, deluge nozzle K-factor distribution, and transient surge mitigation in high-risk chemical networks.

What work product does a participant bring back from fire water hydraulic calculation using PIPENET?

You return with a complete Fire Protection Hydraulic Network Analysis Dossier. This technical document compiles input assumptions, nodal flow balances, friction loss calculations, pump operating curve matching, and transient surge analyses to substantiate fire water network compliance for internal teams and safety authorities.

Fire Water Hydraulic Calculation Using PIPENET: The Way Forward

The Fire Protection Hydraulic Network Analysis Dossier establishes quantitative verification for emergency water distribution, providing the engineering basis to approve pipe sizing, fire pump ratings, and deluge valve settings. Process safety committees and plant modifications teams use this artefact during safety case evaluations. Revisit the model after plant footprint expansions or pipework modifications to maintain protective safety margins.